



STEVEN A. THOMPSON  
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN  
Governor

**PERMIT NO.: SL000014130220**

**SEWER LINES**

**FACILITY NO.: S-20616**

**PERMIT TO CONSTRUCT**

April 24, 2013

Pursuant to O.S. 27A 2-6-304, the Norman Utilities Authority is hereby granted this Tier I Permit for demolition of an existing lift station; construction of approximately 65 L. F. of eight (8) inch and 3,500 L. F. of twelve (12) inch sewer lines; and appurtenances to serve the City of Norman Tecumseh Interceptor Project, located in part of S-1/2 of Section 12 and NW-1/4, NE-1/4, NW-1/4 of Section 13, T-12-N, R-3-W, I. M., Cleveland County, Oklahoma, in accordance with the plans approved on April 24, 2013.

By acceptance of this permit, the permittee agrees to operate and maintain the facilities in accordance with the "Oklahoma Pollutant Discharge Elimination System Standards - OPDES" (OAC 252:606) rules and to comply with the state certification laws, Title 59, Section 1101-1116 O.S. and the rules and regulations adopted thereunder regarding the requirements for certified operators.

This permit is issued subject to the following provisions and conditions.

- 1) That the recipient of the permit is responsible that the project receives supervision and inspection by competent and qualified personnel.
- 2) That construction of all phases of the project will be started within one year of the date of approval or the phases not under construction will be resubmitted for approval as a new project.
- 3) That no significant information necessary for a proper evaluation of the project has been omitted, or invalid information has been presented in applying for the permit.
- 4) That tests will be conducted as necessary to insure that the construction of the sewer lines will prevent excessive infiltration and that the leakage will not exceed 10 gallons per inch of pipe diameter per mile per day.
- 5) That the Oklahoma Department of Environmental Quality shall be kept informed of occurrences which may affect the eventual performance of the works or that will unduly delay the progress of the project.
- 6) That the permittee will take steps to assure that the connection of house services to the sewers is done in such a manner that the functioning of the sewers will not be impaired and that earth and ground water will be excluded from the sewers when the connection is completed.
- 7) The issuance of this permit does not relieve the responsible parties of any obligations or liabilities which the permittee may be under pursuant to prior enforcement action taken by the Department.





STEVEN A. THOMPSON  
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN  
Governor

**PERMIT NO.: SL000014130220**

**SEWER LINES**

**FACILITY NO.: S-20616**

**PERMIT TO CONSTRUCT**

- 8) That any deviations from approved plans or specifications affecting capacity, flow or operation of units must be approved by the Department before any such deviations are made in the construction of this project.
- 9) That the recipient of the permit is responsible for the continued operation and maintenance of these facilities in accordance with rules and regulations adopted by the Environmental Quality Board, and that this Department will be notified in writing of any sale or transfer of ownership of these facilities.
- 10) That the permittee is required to inform the developer/builder that a DEQ Storm Water Construction Permit is required for a construction site that will disturb one (1) acre or more in accordance with OPDES, 27A O.S. 2-6-201 *et. seq.* For information or a copy of the GENERAL PERMIT (GP-005) FOR STORM WATER DISCHARGES FROM CONSTRUCTION ACTIVITIES, Notice of Intent (NOI) form, Notice of Termination (NOT) form, or guidance on preparation of a Pollution Prevention Plan, contact the Storm Water Unit of the Water Quality Division at P.O. Box 1677, Oklahoma City, OK 73101-1677 or by phone at (405) 702-8100.
- 11) That all manholes shall be constructed in accordance with the standards for Water Pollution Control Facility Construction (OAC 252:656-5-3), as adopted by the Oklahoma Department of Environmental Quality.
- 12) That when it is impossible to obtain proper 10-foot horizontal and 2-foot vertical separation between water mains and sewer lines as stipulated in Water Pollution Control Facility Construction OAC 252:656-5-4(c)(1) and OAC 252:656-5-4(c)(2), respectively, the sewer shall be designed and constructed equal to water pipe, and shall be pressure tested with no detectable leakage prior to backfilling, in accordance OAC 252:656-5-4(c)(3).

Failure to appeal the conditions of this permit in writing within 30 days from the date of issue will constitute acceptance of the permit and all conditions and provisions.

Rocky Chen, P.E., Engineering Manager, Construction Permit Section  
Water Quality Division

Page 2 of 2

