



office memorandum

Date: August 26, 2020
To: Beth Muckala, Assistant City Attorney
From: Ken Danner, Subdivision Development Manager
Subject: Consent to Encroach No. 2021-6
Lot 3, Block 1, Stinson Estates Addition
708 Stinson

Public Works Department, Engineering Division does not object to the encroachment of proposed patio and patio cover over a 20' sanitary sewer easement located on the western portion of the lot as long as there is a hold harmless clause in the consent document that clearly states any settlement within the easement is not the responsibility of the City to maintain. The existing sanitary sewer line has been abandoned. We do yield to the Utilities Department for any additional comments. Utility companies were not notified since this encroachment is located within a City-owned sanitary sewer easement.

If you have further questions, please feel free to contact me.

kd
Reviewed by: Scott Sturtz, City Engineer
Reviewed by: Shawn O'Leary, Director of Public Works

cc: Brenda Hall, City Clerk
Ken Komiske, Director of Utilities