



# City of Norman, OK

Municipal Building  
Council Chambers  
201 West Gray  
Norman, OK 73069

## Master

**File Number: GID-1819-11**

**File ID:** GID-1819-11      **Type:** Authorization for Purchase      **Status:** Consent Item

**Version:** 1      **Reference:** Item 13      **In Control:** City Council

**Department:** Utilities Department      **Cost:** \$31,085.00      **File Created:** 08/29/2018

**File Name:** Purchase of 2 Flygt Submersible Pumps for Summit Lakes Lift Station      **Final Action:**

**Title:** CONSIDERATION OF AUTHORIZATION FOR THE PURCHASE OF TWO (2) FLYGT SUBMERSIBLE PUMPS AND MOTORS IN THE AMOUNT OF \$31,085 FROM AUTOMATIC ENGINEERING FOR THE SUMMIT LAKES LIFT STATION.

**Notes:** ACTION NEEDED: Acting as the Norman Utilities Authority, motion to approve or reject authorization for the purchase of two (2) Flygt submersible pumps and motors in the amount of \$31,085 from Automatic Engineering to be used at Summit Lakes Lift Station.

ACTION TAKEN: \_\_\_\_\_

**Agenda Date:** 09/11/2018

**Agenda Number:** 13

**Attachments:** Summit Lakes Pump Quote, Sole Source Letter, Purchase Requisition

**Project Manager:** David Hager, Line Maintenance Supt

**Entered by:** paul.johnston@normanok.gov

**Effective Date:**

### History of Legislative File

Ver- sion:	Acting Body:	Date:	Action:	Sent To:	Due Date:	Return Date:	Result:
---------------	--------------	-------	---------	----------	-----------	-----------------	---------

### Text of Legislative File GID-1819-11

Body

**BACKGROUND:** The annual sewer lift station rehabilitation capital project for Fiscal Year 2018-2019 (FYE 2019) is budgeted and programmed to replace two (2) twenty horsepower (20HP) sewage pumps in the Summit Lakes Lift Station. The Summit Lakes Lift Station was approved by the City of Norman in 2007 with design features for the pump railings, quick disconnect connections (QDSC) and the motor control panel for Paco Pumps.

**DISCUSSION:** Line Maintenance staff was notified by Haynes Equipment, "the authorized dealer for Paco Pumps," that Paco Pumps are no longer being manufactured and the company was sold to Grundfos. According to the Haynes Equipment sales representative, Grundfos manufactures sewage pumps compatible to the Paco Pumps but requires an adapter and modifications to the existing pump railings.

Staff researched for alternative pumps to be used without an adapter and modifications to the existing pump rails and found that Flygt Submersible Pumps manufactures 20 horsepower pumps which meet pump curves and head dynamics for the lift station, without any modifications to the pump, pump railing and the QDSC connections.

Recent discussions with Automatic Engineering, the sole-source provider for Flygt Submersible Pumps, clarified the fact that Flygt Submersible Pumps have the same design and construction of the pump discharge connection as on existing Paco QDSC style pumps. As a result, Flygt pumps may be used as a direct replacement to the Paco Pump requiring no modifications of the pump, guide rail systems or the QDSC connections.

**RECOMMENDATION:** Staff recommends approval of the purchase of two new Flygt NP 3153 20 HP Submersible Pumps and Motors from Automatic Engineering, the authorized representative and sole provider for Flygt Submersible Pumps, at the cost of \$31,085. Funding is available in the Sewer Maintenance Fund, Summit Lakes Lift Station Rehabilitation, Construction (account 321-9234-432.61-01; project WW0320).