

ATTACHMENT 2

The local amendments noted below are considered less stringent than the code adopted by the state and are therefore being recommended for deletion from Chapter 5 of the City Code.

International Building Code IBC

- In occupancies other than assembly, business owners may elect to provide drinking water by a means other than a drinking fountain when the code calculated occupant load is 50 persons or less.
- In occupancies other than assembly, business owners may elect to provide a single user accessible toilet facility when the code calculated occupant load is 50 persons or less.

International Mechanical Code IMC

- For appliances located in attics the access passageway length was modified to read: where not more than 20 feet length of the passageway is a minimum 30 inches high and 22 inches wide, the entire passageway shall be not greater than 50 feet in length.

International Plumbing Code IPC

- In occupancies other than assembly, business owners may elect to provide drinking water by a means other than a drinking fountain when the code calculated occupant load is 50 persons or less.
- In occupancies other than assembly, business owners may elect to provide a single user accessible toilet facility when the code calculated occupant load is 50 persons or less.

National Electrical Code NEC

- Where a multi-wire branch circuit supplies more than one device or equipment on the same yoke, a means shall be provided to disconnect simultaneously all ungrounded conductors supplying those devices or equipment at the point where the branch circuit originates.

- **Outdoors - expand exception provided in Article 426 by adding "as well as, exterior receptacles for outside holiday lighting, so long as the minimum height above adjoining ground area is 7 feet."**
- **Dwelling unit receptacle outlets installed in accordance with 210.52 and lighting outlets installed in accordance with 210.70 shall be limited to a maximum of 14 for 20 ampere and a maximum of 10 for 15 ampere branch circuits.**

International Fuel Gas Code IFGC

- **For appliances located in attics the access passageway length was modified to read: where not more than 20 feet length of the passageway is a minimum 30 inches high and 22 inches wide, the entire passageway shall be not greater than 50 feet in length.**

International Residential Code IRC

- **For appliances located in attics the access passageway length was modified to read: where not more than 20 feet length of the passageway is a minimum 30 inches high and 22 inches wide, the entire passageway shall be not greater than 50 feet in length.**
- **BATHTUBS, delete Section P2713.3 Bathtub and whirlpool bathtub valves; this amendment provided exemption for higher water temperature control.**
- **Dwelling unit receptacle outlets installed in accordance with E3901.1 and lighting outlets installed in accordance with E3903.1 shall be limited to a maximum of 14 for 20 ampere and a maximum of 10 for 15 ampere branch circuits.**
- **Ground-Fault and Arc-Fault Circuit-Interrupter Protection, Section E3902.3 Outdoor receptacles - expand exception provided in Section E4101.7 by adding "as well as, exterior receptacles for outside holiday lighting so long as the minimum height above adjoining ground area is 7 feet."**
- **GROUND-FAULT AND ARC-FAULT CIRCUIT-INTERRUPTER PROTECTION, Section E3902.7 Laundry, utility, and bar sink receptacles. Add "Exception: A single receptacle or duplex**

receptacle for two appliances located within dedicated space for each appliance that in normal use is not easily moved from one place to another, and that is cord and plug connected.