



15525 Coe Loop
Magnolia TX 77355
(281)356-2084 Office
(281)356-3563 Fax
www.cmprepair.com

November 15, 2012

**Greg Hall
City of Norman
Public Works
Street/Storm Water Superintendent**

REF: Triad Village Drive Storm Sewer

Job Analysis: There is a 471' pipe located at Triad Village Drive. The pipe seems to be in good condition. We found a rusted invert that had several holes that need to be repaired. There was also soil loss around the host pipe.

Scope of Work: CMP Repair will reline the existing invert with coated sheet metal. We will fasten the metal to the host pipe using coated fasteners. Inject polyurethane around the host pipe to fill voids and stabilize surrounding soils.

Additional Comments: CMP Repair will provide all tools, material and labor required to complete this job. Barring any extreme weather, we will complete this job within one week.

Job Cost: \$150,720 + applicable taxes

If you have any questions, please contact me and I will be glad to answer all of your concerns.

A handwritten signature in black ink, appearing to read "Mike Bennett".

**Mike Bennett
CMP Repair
mikeb@cmprepair.com
(281)793-0691**