



City of Norman, OK

Municipal Building
Council Chambers
201 West Gray
Norman, OK 73069

Master

File Number: BID-1415-27

File ID: BID-1415-27	Type: Bid	Status: Consent Item
Version: 1	Reference: Item No. 15	In Control: City Council
Department: Utilities Department	Cost:	File Created: 10/05/2014
File Name: Bid for Copper Meter Yokes, Meter boxes and Repair Clamps		Final Action:

Title: CONSIDERATION AND AWARDED OF BID NO. 1415-27 FOR THE PURCHASE OF COPPER METER YOKES FOR WATER METERS, HDPE METER BOXES WITH CAST IRON LIDS, AND WATER LINE REPAIR CLAMPS FOR THE LINE MAINTENANCE DIVISION.

Notes: ACTION NEEDED: Acting as the Norman Utilities Authority, motion to accept or reject all bids meeting specifications for Copper Meter Yokes, HDPE Meter Boxes with Cast Iron Lids, and Water Repair Clamps, Sections 1, 2, 3, 25, 27, 34, 36, 37, and 39; and, if accepted, award the bid to American Waterworks Supply, Inc., as the lowest and best bidder meeting specifications.

ACTION TAKEN: _____

ACTION NEEDED: Acting as the Norman Utilities Authority, motion to accept or reject all bids meeting specifications for Water Repair Clamps, Sections 4, 6, 8, 9, 10, 12, 14, 15-24, 29-33, 35, 38, and 40-42; and, if accepted, award the bid to Ferguson Waterworks as the lowest and best bidder meeting specifications.

ACTION TAKEN: _____

ACTION NEEDED: Acting as the Norman Utilities Authority, motion to accept or reject all bids meeting specifications for Sections 5, 7, 11, 13, 26, and 28; and if accepted, award the bid to HD Supply Waterworks as the lowest and best bidder meeting specifications.

ACTION TAKEN: _____

Agenda Date: 10/28/2014

Agenda Number: 15

Attachments: Bid Tabulation Bid 1415-27.pdf

Project Manager: David Hager, Utilities Manager

Entered by: paul.johnston@normanok.gov

Effective Date:

History of Legislative File

Ver- sion:	Acting Body:	Date:	Action:	Sent To:	Due Date:	Return Date:	Result:

Text of Legislative File BID-1415-27

Body

BACKGROUND. Water Maintenance Crews use repair clamps to effect repairs on ruptured water mains. These clamps come in many lengths and diameters and are used according to the specific type and extent of the break. Division specifications require all-stainless steel repair clamps due to the soil conditions in Norman. Each manufacturer uses stainless steel technology and all repair clamps are compatible among suppliers.

Copper meter yokes are used in connecting the water meter and residential service lines to the City water main. The HDPE (High Density Polyethylene) meter boxes with cast iron lids are used to cover the water meter when installing a new meter service. A purchase of approximately 500-700 copper meter yokes and HDPE meter boxes is foreseen for the fiscal year ending June 30, 2015 (FYE15).

DISCUSSION. Bid No. 1415-27 provides competitive prices for the purchase, on an "as needed" basis, for varied repair clamps, copper meter yokes for water meters, and meter boxes. Seven vendors were invited to bid; five bidders responded. Bids were opened on October 2, 2014. The attached bid tabulation provides a complete accounting of these bids.

Bid prices increased .5% for copper meter yokes due to provisions of the federal Safe Water Drinking Act (SWDA) no-lead brass requirement. Bid prices for stainless steel repair clamps decreased 1 % for some categories over the current contract amounts approved in 2013. Bid prices for high density polyethylene plastic (HDPE) meter boxes increased in cost by 7% from current contract amounts in 2013.

RECOMMENDATION. It is recommended that Bid No. 1415-27 be awarded to the lowest and best bidders as follows:

Copper Meter Yokes for Water Meters

Awarded to: American Waterworks Supply, Inc.

HDPE Meter Boxes with Cast Iron Lids

Awarded to: American Waterworks Supply, Inc.

Water Line Repair Clamps

SECTIONS 4, 6, 8, 9, 10, 12, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 29, 30, 31, 32, 33, 35, 38, 40, 41, and 42 - Awarded to: Ferguson Water Works

SECTIONS 1, 2, 3, 25, 27, 34, 36, 37, and 39 - Awarded to American Waterworks Supply, Inc.

SECTIONS 5, 7, 11, 13, 26, and 28 Awarded to: HD Supply Waterworks

Repair clamps (account 031-5551-462.32.16)

Account Amount - \$60,490

Estimated Expenditure - 12,000

Account Balance Remaining - \$48,490

Meter Yokes, Meter Boxes (account 031-5551-462.32.18)

Account Amount - \$181,334

Estimated Expenditure - 53,175

Account Balance Remaining - \$128,159