



SCOTT A. THOMPSON
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN
Governor

September 29, 2014

Mark Daniels, Utilities Engineer
Norman Utilities Authority
Post Office Box 370
Norman, Oklahoma 73070

Re: Permit No.: WL000014140677
Robinson Tower Tank Mixer Project
PWSID No.: 1020801

Dear Mr. Daniels:

Enclosed is Permit No.: WL000014140677 for the construction of reservoir hydrodynamic tank mixing system and appurtenances to serve the City of Norman Robinson Tower Tank Mixer Project, Cleveland County, Oklahoma.

The project authorized by this permit should be constructed in accordance with the plans approved by this Department on September 29, 2014. Any deviations from the approved plans and specifications affecting capacity, flow or operation of units must be approved, in writing, by the Department before changes are made.

Receipt of this permit should be noted in the minutes of the next regular meeting of the Norman Utilities Authority, after which it should be made a matter of permanent record.

We are returning one (1) set of the approved plans to you and retaining (1) set for our files.

Respectfully,

Robert B. Walker
Construction Permit Section
Water Quality Division

RBW/RC/bg

Enclosure

c: Purcell DEQ Office
David Golden, R. S., Regional Manager, DEQ
S. Shane Smith, P. E., Garver Engineers, LLC





SCOTT A. THOMPSON
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN
Governor

PERMIT NO.: WL000014140677

WATER LINES

PWSID No.: 1020801

PERMIT TO CONSTRUCT

September 29, 2014

Pursuant to O.S. 27A 2-6-304, the Norman Utilities Authority is hereby granted this Tier I Permit to construct a reservoir hydrodynamic tank mixing system and appurtenances to serve the City of Norman Robinson Tower Tank Mixer Project, located in part of SW-1/4, SE-1/4, SW-1/4, Section 19, T-9-N, R-2-W, I. M., Cleveland County, Oklahoma, in accordance with the plans approved on September 29, 2014.

By acceptance of this permit, the permittee agrees to operate and maintain the facility in accordance with the Public Water Supply Operation rules (OAC 252:631) and to comply with the State Certification laws, Title 59, Section 1101-1116 O.S. and the rules and regulations adopted thereunder regarding the requirements for certified operators.

This permit is issued subject to the following provisions and conditions.

- 1) That the recipient of the permit is responsible that the project receives supervision and inspection by competent and qualified personnel.
- 2) That construction of all phases of the project will be started within one year of the date of approval or the phases not under construction will be resubmitted for approval as a new project.
- 3) That no significant information necessary for a proper evaluation of the project has been omitted, or invalid information has been presented in applying for the permit.
- 4) That the Oklahoma Department of Environmental Quality shall be kept informed on occurrences which may affect the eventual performance of the works or that will unduly delay the progress of the project.
- 5) That before placing this facility into service, at least two samples of the water, taken on different days, shall be tested for bacteria to show that it is safe for drinking purposes.
- 6) That any deviations from approved plans or specifications affecting capacity, flow or operation of units must be approved by the Department before any such deviations are made in the construction of this project.
- 7) That the recipient of the permit is responsible for the continued operation and maintenance of these facilities in accordance with rules and regulations adopted by the Environmental Quality Board, and that this Department will be notified in writing of any sale or transfer of ownership of these facilities.





SCOTT A. THOMPSON
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

MARY FALLIN
Governor

PERMIT NO.: WL000014140677

WATER LINES

PWSID No.: 1020801

PERMIT TO CONSTRUCT

- 8) The issuance of this permit does not relieve the responsible parties of any obligations or liabilities which the permittee may be under pursuant to prior enforcement action taken by the Department.
- 9) That whenever plastic pipe is approved and used for potable water, it shall bear the seal of the National Sanitation Foundation and meet the appropriate commercial standards.

Failure to appeal the conditions of this permit in writing within 30 days from the date of issue will constitute acceptance of the permit and all conditions and provisions.

A handwritten signature in blue ink, appearing to read "Rocky Chen", is written over a horizontal line.

Rocky Chen, P.E., Engineering Manager, Construction Permit Section
Water Quality Division

Page 2 of 2

